

ASME A112.19.12-2014
[Revision of ASME A112.19.12-2006 (R2011)]

Wall Mounted, Pedestal Mounted, Adjustable, Elevating, Tilting, and Pivoting Lavatory, Sink, and Shampoo Bowl Carrier Systems and Drain Waste Systems

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

INTENTIONALLY LEFT BLANK

ASME A112.19.12-2014

[Revision of ASME A112.19.12-2006 (R2011)]

Wall Mounted, Pedestal Mounted, Adjustable, Elevating, Tilting, and Pivoting Lavatory, Sink, and Shampoo Bowl Carrier Systems and Drain Waste Systems

AN AMERICAN NATIONAL STANDARD



**The American Society of
Mechanical Engineers**

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: February 17, 2015

This Standard will be revised when the Society approves the issuance of a new edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard. Interpretations are published on the Committee Web page and under go.asme.org/InterpsDatabase. Periodically certain actions of the ASME A112 Committee may be published as Cases. Cases are published on the ASME Web site under the A112 Committee Page at go.asme.org/A112committee as they are issued.

Errata to codes and standards may be posted on the ASME Web site under the Committee Pages to provide corrections to incorrectly published items, or to correct typographical or grammatical errors in codes and standards. Such errata shall be used on the date posted.

The A112 Committee Page can be found at go.asme.org/A112committee. There is an option available to automatically receive an e-mail notification when errata are posted to a particular code or standard. This option can be found on the appropriate Committee Page after selecting "Errata" in the "Publication Information" section.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2015 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

CONTENTS

Foreword	iv
Committee Roster	v
Correspondence With the A112 Committee	vi
1 General	1
2 General Requirements	1
3 Testing	2
4 Marking and Instructions	3

ASMENORMDOC.COM : Click to view the full PDF of ASME A112.19.12 2014

FOREWORD

In 1990, the Americans With Disabilities Act passed in Congress. This Act was intended to increase the accessibility of building elements to those who have limitations in physical ability. As a result of the technological response to the need for greater adaptability of plumbing components for accessibility purposes, this Standard and others are being prepared by ASME Standards Committee A112, Standardization of Plumbing Materials and Equipment.

This Standard relates to performance requirements for wall mounted, pedestal mounted, adjustable, elevating, tilting, and pivoting lavatory, sink, and shampoo bowl carrier systems and drain waste systems. Such systems allow the user to adjust the location of a lavatory, shampoo bowl, or sink upwards and downwards. Some products also adjust from side to side and/or front to back in order to maximize the ease of use of the fixture. Some products also pivot or tilt to allow greater ease of fixture use. The performance tests within this Standard were determined to be commensurate with normal fixture use.

The original Standard and the current revisions were based on standards that were developed by two ad hoc committees of the International Association of Plumbing and Mechanical Officials (IAPMO). The proposed standards were subsequently referred to the ASME A112 Standards Committee for development of an American National Standard.

This revision provides new and improved requirements, and test methods for elevating carrier systems, telescoping standpipe waste systems, elevating sinks, lavatories, and shampoo bowls for use by or with handicapped persons.

Suggestions for improvement of this Standard are welcome. They should be sent to The American Society of Mechanical Engineers; Attn: Secretary, A112 Standards Committee; Two Park Avenue; New York, NY 10016-5990.

This Standard was approved as an American National Standard on December 9, 2014.

ASME A112 COMMITTEE

Standardization of Plumbing Materials and Equipment

(The following is the roster of the Committee at the time of approval of this Standard.)

STANDARDS COMMITTEE OFFICERS

D. W. Viola, *Chair*
S. Rawalpindiwala, *Vice Chair*
A. L. Guzman, *Secretary*

STANDARDS COMMITTEE PERSONNEL

R. K. Adler , City of San Jose	J. Kendzel , American Society of Plumbing Engineers
S. F. Aridi , NSF International	J. M. Koeller , Koeller and Co.
D. Orton , <i>Alternate</i> , NSF International	N. M. Kummerlen , Consultant
J. A. Ballanco , JB Engineering and Code Consulting	C. J. Lagan , American Standard
J. E. Bertrand , Moen, Inc.	M. Malatesta , <i>Alternate</i> , American Standard
A. Bonlender , Bradley	J. W. Lauer , Sloan Valve Co.
R. Burnham , Zurn Industries, LLC	D. Gleiberman , <i>Alternate</i> , Sloan Valve Co.
M. Campos , ICC Evaluation Service, LLC	W. LeVan , Cast Iron Soil Pipe Institute
S. L. Cavanaugh , Cavanaugh Consulting	R. Mata , CSA Group
W. E. Chapin , Professional Code Consulting, LLC	S. Rawalpindiwala , Kohler Co.
P. V. DeMarco , IAPMO	T. J. Stessman , <i>Alternate</i> , Kohler Co.
D. E. Holloway , <i>Alternate</i> , IAPMO	S. A. Remedios , Consultant
N. E. Dickey , CSA Group	G. L. Simmons , Charlotte Pipe & Foundry
G. S. Duren , Code Compliance, Inc.	W. B. Morris , <i>Alternate</i> , Charlotte Pipe & Foundry
R. Emmerson , Consultant	D. W. Viola , IAPMO
R. L. George , Plumb-Tech Design and Consulting Services, LLC	A. Murra , <i>Alternate</i> , IAPMO
A. L. Guzman , The American Society of Mechanical Engineers	F. R. Volgstadt , <i>Contributing Member</i> , Volgstadt & Associates, Inc.
G. W. Harrison , Consultant	J. C. Watson , Elkay
L. Himmelblau , Chicago Faucet	M. Weiss , Weiss Research
	W. C. Whitehead , Whitehead Consulting Services

A112 PROJECT TEAM 19.12 — MOVABLE LAVATORY SYSTEMS

M. Campos , <i>Chair</i> , ICC Evaluation Service, LLC	S. J. Cummings , GWA Bathrooms & Kitchens
A. Bonlender , Bradley	S. Rawalpindiwala , Kohler Co.

CORRESPONDENCE WITH THE A112 COMMITTEE

General. ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions or a Case, and attending Committee meetings. Correspondence should be addressed to:

Secretary, A112 Standards Committee
The American Society of Mechanical Engineers
Two Park Avenue
New York, NY 10016-5990
<http://go.asme.org/Inquiry>

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation.

Proposing a Case. Cases may be issued for the purpose of providing alternative rules when justified, to permit early implementation of an approved revision when the need is urgent, or to provide rules not covered by existing provisions. Cases are effective immediately upon ASME approval and shall be posted on the ASME Committee Web page.

Requests for Cases shall provide a Statement of Need and Background Information. The request should identify the Standard and the paragraph, figure, or table number(s), and be written as a Question and Reply in the same format as existing Cases. Requests for Cases should also indicate the applicable edition(s) of the Standard to which the proposed Case applies.

Interpretations. Upon request, the A112 Standards Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the A112 Standards Committee at go.asme.org/Inquiry.

The request for an interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his/her request in the following format:

Subject:	Cite the applicable paragraph number(s) and the topic of the inquiry.
Edition:	Cite the applicable edition of the Standard for which the interpretation is being requested.
Question:	Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in this format may be rewritten in the appropriate format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Attending Committee Meetings. The A112 Standards Committee regularly holds meetings and/or telephone conferences that are open to the public. Persons wishing to attend any meeting and/or telephone conference should contact the Secretary of the A112 Standards Committee. Future Committee meeting dates and locations can be found on the Committee Page at go.asme.org/A112committee.

WALL MOUNTED, PEDESTAL MOUNTED, ADJUSTABLE, ELEVATING, TILTING, AND PIVOTING LAVATORY, SINK, AND SHAMPOO BOWL CARRIER SYSTEMS AND DRAIN WASTE SYSTEMS

1 GENERAL

1.1 Scope

This Standard establishes physical requirements and tests addressing structural strength; adjustments; materials; drain line hydraulics; and mechanical, material, testing, marking, and documentation requirements for wall mounted and pedestal mounted, adjustable, elevating, tilting, and pivoting lavatory, sink, and shampoo bowl carrier systems and drain waste systems intended to facilitate use by individuals who are physically challenged.

The use of alternate materials or methods are permitted, provided the proposed material and method complies with the performance requirements and intent of this Standard.

1.2 Units of Measurement

Values are stated in U.S. Customary units and the International System of Units (SI). The U.S. Customary units shall be considered as the standard.

In this Standard, gallons (U.S. liquid) per minute is abbreviated as gpm.

1.3 Reference Standards

The following documents form a part of this Standard to the extent specified herein. The latest issue shall apply.

ASME A112.18.2/CSA B125.2, Plumbing Waste Fittings
ASME A112.18.6/CSA B125.6, Flexible Water Connectors

ASME A112.19.1/CSA B45.2, Enamelled Cast Iron and Enamelled Steel Plumbing Fixtures

ASME A112.19.2/CSA B45.1, Ceramic Plumbing Fixtures

ASME A112.19.3/CSA B45.4, Stainless Steel Plumbing Fixtures (Designed for Residential Use)

Publisher: The American Society of Mechanical Engineers (ASME), Two Park Avenue, New York, NY 10016-5900; Order Department: 22 Law Drive, P.O. Box 2900, Fairfield, NJ 07007-2900 (www.asme.org)

ASTM D2564, Solvent Cements for Poly (Vinyl Chloride) (PVC) Plastic Piping Systems

Publisher: ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959 (www.astm.org)

CSA B45.5/IAPMO Z124, Plastic Plumbing Fixtures

Publisher: International Association of Plumbing and Mechanical Officials (IAPMO), 5001 East Philadelphia Street, Ontario, CA 91761 (www.iapmo.org)

Fed Spec RR-W-410, Wire Rope and Strand Mil Spec 20668 Terminal, Wire Rope, Swaging, Eye End

Publisher: Defense Printing Service Detachment Office, Building 4-D, 700 Robbins Avenue, Philadelphia, PA 19111-5094 (www.documentservices.dla.mil)

ICC/ANSI A117.1, Accessible and Usable Buildings and Facilities

Publisher: International Code Council (ICC), 500 New Jersey Avenue, NW, Washington, DC 20001 (www.iccsafe.org)

1.4 Definitions

each junction: the point (junction) at the top end of each pipe or section of pipe or tailpiece where a sealing method is used to make it watertight.

multiple stage: using three or more sizes of pipe or tubing, each one inside another, installed vertically to provide telescoping capabilities, with a sealing mechanism at the top of the lower or outer pipe and the top or bottom of each of the other pieces at the joining point between each of the pieces to make each junction watertight.

single stage: using two sizes of pipe or tubing, one inside the other, installed vertically to provide telescoping capabilities, with a sealing mechanism at the top of the lower or outer pipe at the joining point between the two pieces to make the junction watertight.

2 GENERAL REQUIREMENTS

2.1 Adjustable, Elevating, Tilting, and Pivoting Lavatory, Sink, and Shampoo Bowl Carrier Systems

The adjustable, elevating, tilting, and pivoting lavatory, sink, and shampoo bowl carrier system shall consist of a wall mounted or pedestal mounted carrier with a height adjustment and/or a lateral adjustment mechanism and/or pivot or tilt adjustment, a lavatory or sink

that complies with the dimensional requirements of ICC/ANSI A117.1, a flexible waste system, or telescoping waste system, and a means to supply water to the fixture. The respective waste system shall

- (a) provide drainage of the fixture
- (b) protect the building from sewer gas
- (c) be serviceable and accessible

2.2 Fixture Mounting System

The wall mounted or pedestal mounted adjustment mechanism shall provide the necessary means for mounting the lavatory, sink, or shampoo bowl over the manufacturer's intended range of travel, with an adjustable mechanism to position the fixture either vertically, laterally, or vertically and laterally, or allow the fixture to pivot or tilt up and down.

2.3 Sink, Lavatory, or Shampoo Bowl Fixtures and Flexible Water Supply Connectors

The sink, lavatory, or shampoo bowl fixtures and flexible water supply connectors shall comply with the applicable product standard(s) regarding materials, manufacture, and installation. These include the following (also listed in para. 1.3):

- (a) ASME A112.18.2/CSA B125.2
- (b) ASME A112.18.6/CSA B125.6
- (c) ASME A112.19.1/CSA B45.2
- (d) ASME A112.19.2/CSA B45.1
- (e) ASME A112.19.3/CSA B45.4
- (f) CSA B45.5/IAPMO Z124

2.4 Flexible Waste System and Telescoping Tailpiece Waste System

The trap seal provided by the flexible waste system shall be a minimum of 2 in. (51 mm) in depth, when evaluated in accordance with para. 3.2. Materials used in the construction of the flexible waste system shall be metallic, plastic, or elastomeric that comply with the requirements of para. 3.2 and ASME A112.18.2/CSA B125.2.

2.4.1 Telescoping Tailpiece Construction. The telescoping tailpiece waste system shall have a minimum outside diameter of $1\frac{1}{2}$ in. (39 mm) for sink and shampoo bowls and $1\frac{1}{4}$ in. (32 mm) minimum for lavatory tailpieces. The standpipe may be constructed in either single or multiple stage models for different applications. All moving components shall be designed and constructed to seal with a double O-ring at each junction. The standpipe must always be installed in a vertical position.

2.4.2 Telescoping Tailpiece Waste System Linkage Material. Linkage materials that contain stainless steel cables shall comply with Fed Spec RR-W-410. Cable eyes shall be constructed from 300 Series stainless steel and not to break under a load of 480 lb (217.7 kg), or comply with Mil Spec 20668.

2.4.3 Trap Seal of Flexible Hoses. PVC wastes that contain a flexible waste hose shall be factory solvent welded to the trap or trap adapter using PVC solvent cement complying with ASTM D2564. The flexible hose shall be supported in such a manner that it is prevented from bending to form a second trap.

2.4.4 Pressure and Leakage Tests. The flexible waste system or a telescoping tailpiece waste system shall comply with the pressure and leakage requirements of ASME A112.18.2/CSA B125.2.

2.4.5 Flow Test. The flexible waste system or a telescoping tailpiece waste system shall comply with the flow rate requirements of ASME A112.18.2/CSA B125.2.

2.5 Flexible Water Supply Connectors

Flexible water supply connectors shall comply with ASME A112.18.6/CSA B125.6.

3 TESTING

3.1 Adjustable, Elevating, Tilting, and Pivoting Lavatory, Sink, and Shampoo Bowl Carrier Systems

3.1.1 Load Testing

3.1.1.1 Test Method for Mounting System. The mounting system shall be installed in accordance with the manufacturer's instructions. A load of 250 lb (113.4 kg) shall be applied on the top of the lavatory, sink, or shampoo bowl fixture rim for a period of 15 min, in both its highest and lowest positions. When lateral adjustments are provided, the test shall be conducted to apply the load of 250 lb (113.4 kg) to the carrier. After application of the required load, the assembly shall be inspected for damage. The device shall be operated through its full range of travel.

3.1.1.2 Performance Requirement. The assembly shall demonstrate no sign of damage during and after the application of the load. When the device is operated through its full range of travel, it shall function as it did prior to the load test.

3.1.2 Vertical, Pivotal, and Tilt Adjustment

3.1.2.1 Adjustment. The mounted adjustment mechanism shall provide adjustment for use as specified by the product manufacturer. For an adjustable position or elevating sink, lavatory, or shampoo bowl with specified pivotal and tilt adjustment, the mechanism shall provide a pivot or tilt adjustment of not less than 10 deg and not more than 20 deg. For an adjustable position or elevating sink, lavatory, or shampoo bowl with specified vertical adjustment, the mechanism shall provide vertical adjustment not less than 2 in. (51 mm) and not more than 30 in. (762 mm).

3.1.2.2 Test Method. The assembled system shall be operated throughout its full range of vertical adjustment and the travel shall be measured.

3.1.2.3 Performance Requirement. The carrier shall provide a vertical adjustment of not less than 2 in. (51 mm) and not more than 30 in. (762 mm), and a pivotal or tilted adjustment of not less than 10 deg and not more than 20 deg.

3.2 Flexible Waste System or Telescoping Tailpiece Waste System

3.2.1 Trap Seal

3.2.1.1 Test Method. The wall mounted or pedestal mounted adjustable or elevating lavatory, shampoo bowl, or sink carrier system and flexible waste system or a telescoping tailpiece waste system shall be installed in accordance with the manufacturer's instructions. The lavatory, sink, or shampoo bowl shall be positioned at its lowest position. Fill the trap with water until water flows from the outlet of the flexible waste system or telescoping tailpiece waste system. Measure the depth of the trap seal. After measuring the height difference caused by vertical adjustment, the measurement of the trap seal of the extremes in the lateral, pivoting, or tilting fixture movement shall also be measured. The lavatory, sink, or shampoo bowl shall then be raised to its highest position and the depth of seal shall again be measured.

3.2.1.2 Performance Requirement. The trap seal depth for the flexible waste system or the telescoping tailpiece waste system shall be not less than 2 in. (51 mm) at any position.

3.3 Aging Test for the Flexible Waste System

3.3.1 Test Method. Flexible drain hose shall be aged at atmospheric pressure and elevated temperature. Age a specimen at a temperature of $140^{\circ}\text{F} \pm 3.6^{\circ}\text{F}$ ($60^{\circ}\text{C} \pm 2^{\circ}\text{C}$) for 166 hr.

3.3.2 Performance Requirement. After the exposure, examine the test specimen for surface cracks under $2\times$ magnification. Presence of any cracking shall be cause for failure. In addition, perform the hydrostatic pressure test as described in ASME A112.18.2/CSA B125.2. The flexible waste system shall not leak during the test time period.

3.4 Cycle Test

3.4.1 Flexible Waste System Pivot and Tilt Cycle Test. The assembled joints in the flexible waste hose

system shall be cycle tested. Install the flexible hose to simulate actual installation. Fix the rigid outlet fitting to which the hose is joined at a point $3\text{ in.} \pm \frac{1}{8}\text{ in.}$ ($76.2\text{ mm} \pm 3.2\text{ mm}$) from the inlet end. Attach the flexible hose to the cycling fixture at a point $12\text{ in.} \pm \frac{1}{8}\text{ in.}$ ($304.8\text{ mm} \pm 3.2\text{ mm}$) upstream of the rigid fitting attachment. One cycle shall consist of moving the flexible hose back and forth one time through 20 deg of pivoting or tilting. The 20 deg shall begin at 10 deg from the centerline of the outlet fitting and end 10 deg at the opposite side of the centerline. Cycle the hose 20,000 times at $70^{\circ}\text{F} \pm 5^{\circ}\text{F}$ ($21.1^{\circ}\text{C} \pm 2.8^{\circ}\text{C}$) at a minimum of six cycles per minute. At the conclusion of the 20,000 cycles, perform the pressure test as described in para. 2.4.4. The joint(s) shall not leak.

3.4.2 Flexible Waste System and Telescoping Tailpiece Waste System Vertical Cycle Test. Both assembled waste system assemblies shall be cycle tested. Install each respective waste system to simulate actual installation. Fix the bottom outlet fitting to which the waste system is joined at a point $7\text{ in.} \pm \frac{1}{8}\text{ in.}$ ($177.8\text{ mm} \pm 3.2\text{ mm}$) from the floor. Attach the top end of the waste system to the cycling fixture at a point $19\text{ in.} \pm \frac{1}{8}\text{ in.}$ ($482.6\text{ mm} \pm 3.2\text{ mm}$) above the rigid fitting attachment. One cycle shall consist of moving the waste system up and down one time through its maximum of vertical travel. The vertical travel shall begin at the fully closed position and extend towards the fully extended position. Cycle the waste system 20,000 times at $70^{\circ}\text{F} \pm 5^{\circ}\text{F}$ ($21.1^{\circ}\text{C} \pm 2.8^{\circ}\text{C}$) at a minimum of six cycles per minute. At the conclusion of the 20,000 cycles, perform the pressure test as described in para. 2.4.4. The joint(s) shall not leak.

4 MARKING AND INSTRUCTIONS

4.1 Marking

Each wall mounted or pedestal mounted, adjustable, elevating, tilting, and pivoting lavatory, sink, and shampoo bowl carrier system and drain waste system shall be marked with the following:

- (a) manufacturer's name or trademark permanently applied and visible after installation
- (b) model number

4.2 Instructions

Installation and owner/user instructions shall be supplied with the system, including minimum requirements for structural support for wall mounted systems.

INTENTIONALLY LEFT BLANK

ASMENORMDOC.COM : Click to view the full PDF of ASME A112.19.12 2014