



UL 2748

STANDARD FOR SAFETY

Arcing Fault Quenching Equipment

ULNORM.COM : Click to view the full PDF of UL 2748 2020

ULNORM.COM : Click to view the full PDF of UL 2748 2020

**UL COPYRIGHTED MATERIAL – NOT AUTHORIZED FOR FURTHER
REPRODUCTION OR DISTRIBUTION WITHOUT PERMISSION FROM UL INC.**

UL Standard for Safety for Arcing Fault Quenching Equipment, UL 2748

First Edition, Dated September 22, 2017

SUMMARY OF TOPICS

This revision of ANSI/UL 2748 dated October 26, 2020 includes the correction of an editorial error of a Standard reference in paragraph [14.6](#)

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

The revised requirements are substantially in accordance with Proposal(s) on this subject dated August 21, 2020.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 2748 2020

SEPTEMBER 22, 2017
(Title Page Reprinted: October 26, 2020)



1

UL 2748

Standard for Arcing Fault Quenching Equipment

Prior to the first edition, the requirements for the products covered by this standard were included in the Outline of Investigation for Arcing Fault Quenching Equipment, UL 2748.

First Edition

September 22, 2017

This ANSI/UL Standard for Safety consists of the First Edition including revisions through October 26, 2020.

The most recent designation of ANSI/UL 2748 as an American National Standard (ANSI) occurred on October 16, 2020. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2020 UNDERWRITERS LABORATORIES INC.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 2748 2020

CONTENTS**INTRODUCTION**

1	Scope	5
2	Components	5
3	Units of Measurement	5
4	Undated References	5
5	Glossary	6

CONSTRUCTION

6	General	6
7	Enclosure	6
8	Primary or Power Carrying Circuits	7
9	Grounding	7
10	Control and Secondary Wiring	7
11	Creepage and Clearance Distance	7
12	Wiring	8
13	Operation	8

PERFORMANCE

14	General	9
15	Continuous Current Test	9
16	Power-Frequency Withstand Voltage Tests	10
17	Maximum Withstand Current Test	10
18	Internal Arcing Fault Test	11
19	Arc Transfer Test	12
19A	Mechanical Endurance	12

RATINGS

20	General	12
----	---------------	----

MARKING

21	General	13
----	---------------	----

INSTRUCTIONS

22	General	14
----	---------------	----

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 2748 2020

INTRODUCTION

1 Scope

1.1 These requirements cover equipment intended to quench arcing faults by creating a lower impedance current path, located within a controlled compartment, to cause the arcing fault to transfer to the new current path.

1.2 These requirements cover equipment that may either be completely enclosed units or intended to be installed within power distribution equipment.

1.3 These requirements cover equipment rated up to 52 kV ac maximum.

1.4 This standard does not include the requirements for arc detection relays and related sensors intended to detect arcing faults or devices that are intended to interrupt arcing fault currents.

1.5 This standard does not include all the requirements for integration and testing of arc quenching equipment within equipment it is intended to protect.

1.6 This standard does not contain requirements for investigation of the performance of an entire arc mitigation system, which would consist of arc sensors, relays, quenching equipment and other ancillary equipment necessary to form a complete system.

2 Components

2.1 Except as indicated in [2.2](#), a component of a product covered by this standard shall comply with the requirements for that component.

2.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

2.3 A component shall be used in accordance with its rating established for the intended conditions of use.

2.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

3 Units of Measurement

3.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

4 Undated References

4.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

5 Glossary

5.1 For the purpose of this standard, the following definitions apply.

5.2 ARCING FAULT – A non-intentional discharge of electrical energy in air or other gas, including discharges across the surface of an insulating material.

5.3 ARC TRANSFER TIME – The interval between triggering of the arc quenching device and the quenching of the arcing fault.

5.4 CONTROLLED COMPARTMENT – A portion of equipment, intended to enclose the new current path when an arcing fault is transferred. This compartment may be provided with openings or flaps for pressure relief.

5.5 LOW-VOLTAGE – A voltage of 1000 V ac or less.

5.6 MEDIUM-VOLTAGE – A voltage of greater than 1000 V ac, up to 52 kV ac.

5.7 POLLUTION DEGREE 2 MICROENVIRONMENT – An area where normally, only nonconductive pollution occurs, but where occasional, temporary conductivity may be expected. Typical constructions that reduce the possibilities of conductive pollution and condensation or high humidity are:

- a) Un-ventilated enclosures that are provided with continuous application of heat through the use of heaters or through continuous energization of the equipment, with interruptions such that cooling to the point of condensation does not occur or
- b) The use of ventilated enclosures where all openings are provided with filters.

5.8 QUENCHING DEVICE – Equipment that is used to extinguish or redirect an arcing fault.

5.9 RESETTABLE (as applied to quenching devices) – capable of being reset and returned to service without replacement or repair of components.

CONSTRUCTION

6 General

6.1 Where referenced in this standard, requirements contained in the Standard for Metal-Enclosed Low-Voltage Power Circuit Breaker Switchgear, UL 1558, are applicable to low-voltage quenching devices, and the requirements contained in Metal-Enclosed Interrupter Switchgear, IEEE C37.20.3 are applicable to medium-voltage quenching devices.

7 Enclosure

7.1 Other than as noted in [7.2](#), quenching devices shall comply with the requirements of [7.3 – 7.6](#).

7.2 Devices covered by this standard that are intended for installation completely within the enclosure of other equipment need not be provided with an enclosure.

7.3 Low-voltage devices provided with complete enclosures shall comply with the enclosure requirements of the Standard for Metal-Enclosed Low-Voltage Power Circuit Breaker Switchgear, UL 1558. Medium-voltage devices provided with complete enclosures shall comply with the enclosure requirements of Metal-Enclosed Interrupter Switchgear, IEEE C37.20.3.

7.4 Where a portion of the quenching device is intended to fill or protrude through an opening, or otherwise form a portion of the enclosure of the overall equipment, it shall be investigated in accordance with the enclosure requirements of the standard for the overall equipment.

7.5 Devices described in [7.3](#) and [7.4](#) may be assigned one or more enclosure type designations in accordance with [21.10](#). The devices shall comply with the requirements of the Standard for Enclosure for Electrical Equipment, Environmental Considerations, UL 50E for each assigned type designation when installed.

7.6 Gaskets relied upon to maintain the environmental rating of the equipment shall comply with the gasket requirements of the Standard for Enclosure for Electrical Equipment, Environmental Considerations, UL 50E.

8 Primary or Power Carrying Circuits

8.1 Low-voltage equipment shall comply with Section [6](#), Primary or Power Carrying Circuits, of the Standard for Metal-Enclosed Low-Voltage Power Circuit Breaker Switchgear, UL 1558.

8.2 Medium-voltage equipment shall comply with Section [7.1](#), Buses and primary connections, of Metal-Enclosed Interrupter Switchgear, IEEE C37.20.3.

9 Grounding

9.1 There shall be provision for grounding all non-current carrying metal parts of the equipment. In addition, the following parts shall be grounded:

- a) The metal case of a frame or instrument transformer;
- b) The metal case of an instrument, meter or relay; and
- c) The secondary circuit of a current or voltage transformer, if there are provision for field connection to the secondary circuit. Secondary circuits that are not intended for field connection are not required to be grounded..

9.2 The case of an instrument, relay, meter, or similar device, if mounted on a grounded metal surface and secured thereto by means of metal screws, is considered to be grounded.

10 Control and Secondary Wiring

10.1 An insulated conductor provided as part of a control circuit or secondary wiring shall be rated for the particular application and shall have an ampacity not less than the continuous current rating of the circuit in which it is connected. Where loads are of an intermittent nature, such as in trip and closing circuits, conductors shall be sized to provide their intended function with respect to voltage drop and mechanical strength.

11 Creepage and Clearance Distance

11.1 Section [12](#), Spacings, of the Standard for Metal-Enclosed Low-Voltage Power Circuit Breaker Switchgear, UL 1558 applies to the power circuits of low-voltage quenching equipment, other than as noted in [11.3](#).

11.2 No minimum creepage or clearance distances are specified for medium-voltage circuits in quenching equipment, other than distances sufficient to meet the dielectric requirements specified in this standard for the voltage rating of the equipment.

11.3 No minimum creepage or clearance distances are specified across the contacts of the quenching means when these contacts are contained within a pollution degree 2 microenvironment, and the quenching equipment meets the dielectric test requirements of this standard with the quenching device in the open position.

11.4 Creepage and clearance distances within low-voltage control circuits of quenching devices shall comply with the creepage and clearance distance requirements of the Standard for Industrial Control Equipment, UL 508 or the Standard for Low-Voltage Switchgear and Controlgear – Part 1: General rules, UL 60947-1. Creepage and clearance distances between low-voltage control circuits and medium-voltage circuits shall be no smaller than the creepage and clearance distances required from the medium-voltage circuit to grounded metal, and shall also be sufficient to meet the dielectric requirements specified in this standard for the maximum voltage rating of the equipment, with the control circuits grounded during testing.

11.5 The pollution degree 2 microenvironment specified in [11.3](#) need not be maintained during or after the quenching of an arcing fault if servicing of the quenching means is required after an arcing fault event, and the quenching means is marked in accordance with [21.5](#).

11.6 For printed wiring boards, the creepage and clearance distances shall comply with requirements of the Standard for Insulation Coordination Including Clearance and Creepage Distances for Electrical Equipment, UL 840. For the purpose of determining required creepage and clearance distances, quenching devices shall be considered to be located within circuits of overvoltage category 3. All quenching devices are considered to be installed in pollution degree 3 environments, except for portions of the device located in a pollution degree 2 microenvironment.

11.7 Pollution Degree 2 shall be considered to exist on a printed-wiring board where a coating provides an uninterrupted covering of the conductive material for at least one of two conductive materials and covers the entire space between the two conductive materials for which the spacing is being evaluated.

12 Wiring

12.1 Insulated conductors provided as part of a quenching device shall be rated for the particular application and shall have an ampacity no less than the maximum current rating of the circuit to which they are connected.

12.2 Wiring shall be located or protected to prevent contact with any sharp edge or moving part that could damage the insulation.

12.3 Insulated conductors shall be separated from wiring and uninsulated live parts connected to other circuits, unless both circuits are provided with insulation rated for the highest voltage.

13 Operation

13.1 Quenching devices with adjustable sensitivity shall comply with the requirements of this standard over the entire range of possible settings.

13.2 Quenching devices that have provisions for disabling the quenching function shall have provisions for local and remote indication that the device has been disabled. Devices with provisions for intentionally delaying the time between detection of an arcing fault and operation of the quenching function shall have provisions for local and remote indication that operation of the quenching function will be intentionally delayed.

13.3 Quenching devices shall be provided with visual indication that the quenching function has operated. Devices shall also have provisions for remote indication of quenching function operation.

13.4 Quenching devices that are intended to be replaced or serviced after every quenching function operation shall have provisions for interlocking such that the circuit protected by the quenching device cannot be reenergized until the quenching device has been replaced or serviced. These devices shall be marked in accordance with 21.5. While mechanical interlocking is preferred, where mechanical interlocking is not practicable, electrical interlocking is acceptable.

PERFORMANCE

14 General

14.1 Quenching devices shall comply with the requirements of this section with the quenching device installed and connected in accordance with the manufacturer's installation instructions.

14.2 Quenching devices with adjustable settings shall be tested to demonstrate compliance with the performance requirements over the range of possible settings, including minimum and maximum settings.

14.3 When provided, output circuits for energizing the trip coils of circuit breakers shall comply with the requirements for Make, Carry, and Interrupt Ratings for Tripping Output Circuits as detailed in the Standard for Relays and Relay Systems Associated with Electric Power Apparatus, IEEE C37.90.

14.4 Arc mitigation equipment that is provided with electronic circuitry shall meet the requirements of the Standard for Surge Withstand Capability (SWC) Tests for Relays and Relay Systems Associated with Electrical Power Apparatus, IEEE C37.90.1.

14.5 Arc mitigation equipment that is provided with electronic circuitry shall meet the requirements of the Standard for Withstand Capability of Relay Systems to Radiated Electromagnetic Interference from Transceivers, IEEE C37.90.2.

14.6 Arc mitigation equipment that is provided with electronic circuitry shall meet the requirements of the Standard for Electrostatic Discharge Tests for Protective Relays, IEEE C37.90.3.

14.7 Insulating materials in contact with medium-voltage parts, or used to isolate medium-voltage parts, shall comply with 6.2.7, Tests for Insulating Materials, of the Standard for Metal Clad Switchgear, IEEE C37.20.2.

15 Continuous Current Test

15.1 Other than as noted in 15.3, low-voltage quenching devices shall be subjected to a continuous current test in accordance with Metal-Enclosed Low-Voltage AC Power Circuit Breaker Switchgear Assemblies – Conformance Test Procedures, ANSI/NEMA C37.51. During the continuous current test, the device shall operate without exceeding the allowable temperature limits specified in Tables 3 and 4 of the Standard for Metal-Enclosed Low-Voltage (1000 Vac and below, 3200 Vdc and below) Power Circuit Breaker Switchgear, IEEE C37.20.1, and in Maximum temperature rises, Table 43.1 and Maximum enclosure surface temperature rises, Table 43.1A of the Standard for Industrial Control Equipment, UL 508 or the Standard for Low-Voltage Switchgear and Controlgear – Part 1: General Rules, UL 60947-1.

15.2 Other than as noted in 15.3, medium-voltage quenching devices shall be subjected to a continuous current test in accordance with Metal-Enclosed Interrupter Switchgear Assemblies – Conformance Testing, ANSI/NEMA C37.57. During the continuous current test, the device shall operate without exceeding the allowable temperature limits specified in Table 2 of Metal-Enclosed Interrupter Switchgear, IEEE C37.20.3, and in Maximum temperature rises, Table 43.1 and Maximum enclosure surface temperature rises, Table 43.1A of the Standard for Industrial Control Equipment, UL 508 or the Standard for Low-Voltage Switchgear and Controlgear – Part 1: General Rules, UL 60947-1.

15.3 Quenching devices that do not carry the current of the main circuit under normal conditions, and conduct only during the quenching operation, are not required to carry this current during the continuous current test. Control circuits that are energized under normal conditions shall be tested in accordance with the continuous current test specified in the Standard for Industrial Control Equipment, UL 508 or the Standard for Low-Voltage Switchgear and Controlgear – Part 1: General Rules, UL 60947-1.

16 Power-Frequency Withstand Voltage Tests

16.1 Low-voltage quenching devices shall comply with the power-frequency withstand voltage tests of Metal-Enclosed Low-Voltage AC Power Circuit Breaker Switchgear Assemblies – Conformance Test Procedures, ANSI/NEMA C37.51.

16.2 Medium-voltage quenching devices shall comply with the power-frequency withstand voltage tests of Metal-Enclosed Interrupter Switchgear Assemblies – Conformance Testing, ANSI/NEMA C37.57.

17 Maximum Withstand Current Test

17.1 Quenching devices shall be subjected to a maximum withstand current test to demonstrate the ability of the quenching device, including the bus and connections, to carry current equal to the maximum arcing fault current rating assigned to the device for the rating short-time withstand duration.

17.2 The test method for low-voltage quenching devices shall be similar to the Short-Time Withstand Current Test method described in Metal-Enclosed Low-Voltage AC Power Circuit Breaker Switchgear Assemblies – Conformance Test Procedures, ANSI/NEMA C37.51, with the following modifications:

- a) The available short-time withstand current shall be calibrated at the line terminals of the equipment in which the quenching device is installed during the test. Calibration of the test circuit shall demonstrate the circuit is capable of delivering the rated maximum withstand current for the entire rated short-time withstand current duration of the quenching device.
- b) The short-time withstand current is to be initiated by action of the quenching device. Alternatively, the test may be conducted using a previously triggered quenching device, by closing the test station switching device onto the circuit. The current is to be maintained for no less than the rated short-time withstand current duration of the quenching device. The actual current through the quenching device is to be measured during the duration of the test. The actual current delivered to the test point will be reduced by the impedance of the arc and the test sample.
- c) Tests shall be conducted with a three phase source of supply. Testing with a single phase source of supply is not representative of three phase testing.
- d) The quenching device shall carry the test current for the entire duration of the test. Interruption of the test current prior to rated short-time withstand current duration shall be considered an unacceptable result.
- e) The contacts of the quenching device may be welded in the closed position at the conclusion of the test. Quenching devices complying with [13.4](#) are not required to be functional at the conclusion of the test.
- f) All local and remote indication means provided shall indicate that the arc quenching function has operated, and shall not reset automatically.
- g) Quenching devices that are intended to be reset, rather than repaired or replaced, after a quenching operation shall meet the required electrical creepage and clearance distances of Section [11](#) after the device has been reset following the short-time withstand test. Quenching devices that require repair or replacement after a quenching operation are not required to meet the required creepage and clearances at the conclusion of the short-time withstand test.

17.3 The test method for medium-voltage quenching devices shall be similar to the Short-Time Withstand Current Test method described in Metal-Enclosed Interrupter Switchgear Assemblies – Conformance Testing, ANSI/NEMA C37.57, with the following modifications:

- a) The available short-time withstand current shall be calibrated at the line terminals of the equipment in which the quenching device is installed during the test. Calibration of the test circuit shall demonstrate the circuit is capable of delivering the rated maximum arcing fault current for the entire rated short-time withstand current duration of the quenching device.
- b) The short-time withstand current is to be initiated by action of the quenching device. Alternatively, the test may be conducted using a previously triggered quenching device, by closing the test station switching device onto the circuit. The current is to be maintained for no less than the rated short-time withstand current duration of the quenching device. The actual current through the quenching device is to be measured during the duration of the test. The actual current delivered to the test point will be reduced by the impedance of the arc and the test sample.
- c) Tests shall be conducted with a three phase source of supply. Testing with a single phase source of supply is not representative of three phase testing.
- d) The quenching device shall carry the test current for the entire duration of the test. Interruption of the test current prior to rated short-time withstand current duration shall be considered an unacceptable result.
- e) The contacts of the quenching device may be welded in the closed position at the conclusion of the test. Quenching devices complying with [13.4](#) are not required to be functional at the conclusion of the test.
- f) All local and remote indication means provided shall indicate that the arc quenching function has operated, and shall not reset automatically.

18 Internal Arcing Fault Test

18.1 The purpose of this test is to demonstrate the quenching device does not create an arc fault hazard during the quenching operation. The quenching device shall be installed in complete equipment in accordance with the manufacturer's installation instructions, or may be tested as an open device without an enclosure. The equipment shall be subjected to testing in accordance with the Guide for Testing Metal-Enclosed Switchgear Rated Up to 38 kV for Internal Arcing Faults, IEEE C37.20.7.

18.2 When tested in complete equipment, indicators shall be provided around the vertical section of the equipment containing the quenching device. Indicator placement shall be in accordance with the requirements of the Guide for Testing Metal-Enclosed Switchgear Rated Up to 38 kV for Internal Arcing Faults, IEEE C37.20.7 for the accessibility type of the equipment containing the arc quenching device. When tested as an open device, indicators shall be placed around the entire quenching device in a similar manner, at a distance of 4 inches from each surface of the quenching device.

18.3 The arc initiation wire shall be in accordance with the requirements of the appropriate Annex of the Guide for Testing Metal-Enclosed Switchgear Rated Up to 38 kV for Internal Arcing Faults, IEEE C37.20.7, based upon the type of equipment in which the quenching device is intended to be installed. The arc shall be initiated within the circuit that is protected by the arc quenching device. The arc initiation is not required to be within the compartment or vertical section containing the quenching device. When a quenching device is intended for use in more than one type of equipment, it may be necessary to conduct testing using arc initiation wires in accordance with more than one Annex from the Guide for Testing Metal-Enclosed Switchgear Rated Up to 38 kV for Internal Arcing Faults, IEEE C37.20.7.

18.4 When testing as an open device, the test is considered acceptable if there is no ignition of any indicators, and no evidence of damage to the quenching device other than contact welding at the